



## POOL / SPA DAILY MAINTENANCE LOG

California Code of Regulations, Title 22, Section 65523:

- A. The operator of each pool open for use shall keep a daily record of information regarding operation, including reading of disinfectant (e.g., chlorine) residual, pH, and maintenance procedures such as cleaning of filters and quantity of chemicals used.
- B. If cyanuric acid (stabilizer) is added to the pool, the concentration shall be measured a minimum of once per month and records shall be kept of the results.

Facility:			
Month:	Year:	Capacity (gal):	Required flow rate (gpm)

Date	Morning		Afternoon		Note
	pH	Chlorine	pH	Chlorine	
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

Monthly Cyanuric Acid Test – Testing Date:	Result:
--	---------

**Reminders**

Free Chlorine Residual:	pH	Cyanuric acid:	Maximum water
2.0ppm minimum for pool with stabilizer	Operational range: 7.2 to 7.8	Less than 100 ppm	temperature: 104°F
3.0ppm minimum for spa with stabilizer	Ideal 7.4 to 7.6	Ideal 30 to 50ppm	
1.0ppm minimum without stabilizer			

Questions? Please call Tulare County Environmental Health Services at (559) 624-7400