



Tulare County

Environmental Health Branch ~ Recreational Health Program



Public Swimming Pool Self-Inspection Checklist

Is Your Pool Ready for Eager Swimmers?

Will your guests swim safely?

- Life ring, body hook, safety rope
- Anti-entrapment devices are installed
- Self-closing gate & approved fencing
- Spa shut-off works

Do you have all your signs?

- No lifeguard (if applicable)
- Occupant capacity
- Artificial respiration & CPR
- Emergency numbers
- No diving (if pool is less than 6' deep)
- Diarrhea warning
- Spa precautions & emergency shut-off
- Keep gates & doors closed

How does your pool look?

- Clear; no debris or algae growth
- Water level at the mid-point of skimmers
- Recirculation equipment turned on during operating hours

How is your pool maintained?

- New test reagents
- Chlorine is above 1 ppm
- pH is 7.2-7.8
- Cyanuric acid is below 100 ppm
- All equipment is in good condition
- Daily log is completed every day
- Supplemental chemicals are on-site
- Skimmers are cleaned daily



CONGRATULATIONS!

*If you checked all of the boxes in this mini-checklist,
Your pool and spa appear to be ready for your guests to enjoy!*

Remember: If your pool's Cyanuric Acid levels are above 100ppm, TAKE ACTION to eliminate buildup of Cyanuric Acid and prevent possible pool closure!

**Management Companies: Please provide keys for properties that do not have an onsite office to: Tulare County Environmental Health Division
5957 South Mooney Blvd; Visalia, CA 93277**

*For questions, please **contact** TCEHD at (559) 624-7400*